

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

## TEST REPORT

**Client :** Real World Epoxies  
19/10 Miltiadis St  
Acacia Ridge QLD 4110

**Test Number :** 21-004850  
**Issue Date :** 8/11/2021  
**Print Date :** 8/11/2021

**Sample Description** Clients Ref : "Resin Rustic with EzyPoly Matte"  
Epoxy resin applied to cement sheet  
Colour : Concrete  
End Use : Flooring  
Nominal Composition : Epoxy/Polyurethane  
Nominal Mass per Unit Area/Density : 3825g/m2  
Nominal Thickness : Approx 2mm

### AS ISO 9239.1-2003

#### Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 17-09-2021

Date Tested 08-11-2021

CHF Value	1	2	3	Mean
Non Directional	7.9	8.1	9.4	8.5 kW/m <sup>2</sup>

Smoke Value	1	2	3	Mean
Non Directional	218	204	104	175 %min

Melting Yes

253713

54398

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved




Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

  
Fiona McDonald  
APPROVED SIGNATORY

  
MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Real World Epoxies  
19/10 Miltiadis St  
Acacia Ridge QLD 4110

**Test Number :** 21-004850  
**Issue Date :** 8/11/2021  
**Print Date :** 8/11/2021

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

No directional properties, three specimens tested only.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

253713

54398

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved




Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

  
Fiona McDonald  
APPROVED SIGNATORY

  
MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR